INSTALLATION AND MAINTENANCE



K101-C Cooling Thermostat





Specifications:

Thermostat is suitable for line voltage cooling systems. Power Supply AC 120V / 208V / 244V / 277V

Maximum Power:

2640W @ 120VAC (22A)

4576W @208VAC (22A)

5280W @ 240VAC (22A)

4986W @ 277VAC (18A)

Sensing Element: Bimetal Temperature Operating Range:

41°F-90°F (3°C—32°C)

cETL us listing.



$\dot{\mathbb{N}}$

WARNING



READ CAREFULLY - These instructions will help prevent difficulties that might arise during thermostat installation. Studying the instructions first may save considerable time and money later. Observing the following procedures will keep installation time to a minimum. Save these instructions for future use.

FUNCTIONS AND FEATURES

- 120/208/240/277 Volts
- · Both °C & °F control dials included
- Wall mount design

 Sits flush against wall
- Fully vented cover allows air sensing in all directions
- Large knob allows easy adjustment to all temperatures
- · Beveled face gives modern appearance
- No Ground wire design
- Mounts directly to a 2x4 inch vertical electrical outlet box

INSTALLATION INSTRUCTIONS

Warning: Turn OFF the power at the circuit breaker before Installing. Installation should be performed by a qualified electrician.

Refer to thermostat and heater load specifications before installation of the thermostat to see if it can handle the amp load. The maximum this thermostat can run is 6925 Watts at 277 Volts, 6000 Watts at 240 Volts, 5200 Watts at 208 Volts and 3000 Watts at 120 Volts.

Install unit in a grounded metal or plastic wall junction box, indoors 4 ½' to 5' above the floor. Avoid any area where it can come in contact with external sources of heat and cold. This includes plumbing pipes, direct sunlight, a T.V. set, lamps, and drafts from a door or window, as this may cause inaccurate temperature readings. The most convenient place is above the light switch. Not for Outdoor use.

KING ELECTRIC MFG CO · 9131 10TH AVENUE SOUTH · SEATTLE, WA 98108 · PH:206 762 0400 · FAX: 206 763 7738 · www.king-electric.com

Rev. 06.04.25

INSTALLATION CONTINUED



SAFETY DATA TO AVOID PROPERTY DAMAGE AND


The installation of the thermostat must comply with the applicable local and/or national electrical code and utility requirements. This installation should be performed by a qualified electrician where required by law. Ensure that all wiring connections to the thermostat are correct and tight to prevent electrical shorts. Use the appropriate wire to meet local and national electrical codes for rated power consumption.

WIRING INSTRUCTIONS

Single Pole Thermostat Installation

- Disconnect power supply to prevent electrical shock or damage to the product.
- 2. Run line voltage wiring to the location of thermostat.
- Connect the red LINE lead on the thermostat to L1 line from the power supply panel.
- 4. Connect the black LOAD lead from the thermostat to the line lead on the heater.
- 5. Connect N Neutral (L2) line to the remaining line of the heater.
- Secure the ground wire to the ground screw provided in the junction box.
- 7. Make sure wire connections are tight.
- Insert wires into the junction box, making sure not to damage wiring
- Remove the thermostat cover by grabbing the cover from the sides and pulling it away from base.
- Mount the thermostat base onto the junction box and secure using the provided screws.





PRODUCT SETUP AND SETTINGS

To adjust the temperature to your requirements, turn the dial on the thermostat clockwise all the way to turn fan on. When he room reaches the desired temperature, turn the thermostat knob counter clockwise until you hear the click. Leave in this position to maintain the room temperature at this setting. For additional cooling, turn clockwise until you the click and the heater will turn on.

Single pole models—Turning knob fully counter clockwise will set the temperature rating to 90°F.

Changing °C and °F control dials

Use a small flathead screwdriver to pry off the control dial. Insert into one of the slots on the dial and gentle apply pressure to remove. To install the new control dial, line up the pins on the dial with the holes on the thermostat knob. Push together urtil secured into place.

KING ELECTRIC MFG CO \cdot 9131 10TH AVENUE SOUTH \cdot SEATTLE, WA 98108 \cdot PH:206 762 0400 \cdot FAX: 206 763 7738 \cdot www.king-electric.com

Rev. 06.04.25